

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| 3 Flags Motorsports Park Well [21936] | 26-Aug-10 No. 4 - Regina Qu'Appelle Regional Health Authority | EBWO - Three Flags Motorsports Park | | 1 | Operational: Undetermined source of contamination Quality: E.coli detected in drinking water system |
| All Season Service [238] | 17-Feb-11 Prince Albert Parkland Regional Health Authority | EBWO- All Season Service, Candle Lake, SK | | 1 | Operational: Does not meet reporting requirements Quality: E.coli detected in drinking water system |
| All Seasons Resort Water System [24146] | 14-Jul-11 Prairie North Regional Health Authority | All Seasons Resort - Turtle Lake EBWO | | 1 | Operational: Does not meet minimum treatment/design requirements Quality: |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| Angler Trail Resort Ltd. (Darsana Property) [22007] | 11-Jun-09 Mamawetan Churchill River Regional Health Authority | PDWA for Angler Trail Resort Ltd. (Darsana Property) [22007] | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Approved Home of June Falkowski [13887] located - SW 14-28-05 W2 | 19-Mar-08 Sunrise Regional Health Authority | PDWA for Approved Home of June Falkowski due to total coliforms, E.coli. & lack of water sampling | | 1 | Operational: Does not meet monitoring requirements Quality: E.coli detected in drinking water system |
| Arctic Lodges Ltd. [15000] | 04-Sep-10 Mamawetan Churchill River Regional Health Authority | PDWA - Arctic Lodges Ltd due to detection of total coliforms | 1 | | Operational: Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|--|------|------|--|
| Athabasca Fishing Lodges - Engler Lake Lodge [15232] | 01-Jul-07 Mamawetan Churchill River Regional Health Authority | EBWO for Athabasca Fishing Lodges - Engler Lake due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Balgonie Shell Well [16976] | 09-May-11 No. 4 - Regina Qu'Appelle Regional Health Authority | PDWA Balgonie Shell Well due to unsatisfactory sampling requirements | 1 | | Operational: Does not meet monitoring requirements Quality: |
| Baptiste Lake Lodge [22000] | 05-Jun-09 Mamawetan Churchill River Regional Health Authority | PDWA for Baptiste Lake Lodge Ltd. due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|--|
| Bayside Bed and Breakfast [15494] | 16-Jun-08 Mamawetan Churchill River Regional Health Authority | PDWA - Bayside Bed and Breakfast due to detection of total coliforms | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Besnard Lake Campground [15994] | 29-Aug-11 Mamawetan Churchill River Regional Health Authority | Besnard Lake Campground | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Bethany College Well #1 (Admin Bldg) [6247] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Bethany College Well #1 (Admin Building) | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|--|
| Bethany College Well #2 (Mens Well) [14598] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Bethany College - Well #2 (Men's Well) | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| Bethany College Well #3 (Centre Court Well) [14599] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Bethany College - Well #3 (Centre Court Well) | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| Bethany College Well #4 (Kitchen) [14603] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Bethany College - Well #4 (Kitchen Well) | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|--|
| Big Sandy Lake Outdoor Adventures [15820] | 26-Jun-06 Mamawetan Churchill River Regional Health Authority | EBWO for Big Sandy Outdoor Adventures due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Bigstone Outfitters [12500] | 17-Jun-11 Mamawetan Churchill River Regional Health Authority | PDWA Issued at Bigstone Outfitters due to detection of total coliforms in drinking water | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Black Bear Island Lodge [14691] | 08-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for Black Bear Island Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|---|--|------|------|--|
| Brunanskys Foster Lake Lodge [17234] | 21-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for Brunansky's Foster Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Buffalo Hump Community Well [13770] RM of Livingston #331 (NW 1/4 7-34-32-W2M) | 18-Mar-09 Sunrise Regional Health Authority | PDWA for Buffalo Hump Community Well [13770] RM of Livingston #331 (NW 1/4 7-34-32-W2M) -coliforms | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Burbidge Lake Lodge Ltd. [16531] | 25-Jun-07 Mamawetan Churchill River Regional Health Authority | EBWO for Burbidge Lake Lodge Ltd. due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|--|
| Burym Community Well [13739] #13739; SW 26-36-3-W2, RM of Clayton #333 | 08-Aug-08 Sunrise Regional Health Authority | PDWA for Burym Community Well #13739; SW 26-36-3-W2, RM of Clayton #333 due to coliform bacteria | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Camp Grizzly [12291] | 09-Jun-09 Mamawetan Churchill River Regional Health Authority | PDWA for Camp Grizzly due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Canadian Wilderness Sports Camp [20863] | 20-Jun-08 Mamawetan Churchill River Regional Health Authority | PDWA for Canadian Wilderness Sports Camp due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|---|
| Cando School Well [15926] | 16-Sep-10 Heartland Regional Health Authority | Cando School and Childcare Centre PDWA | 1 | | Operational: Undetermined source of contamination Quality: Source water contamination |
| Canora Beach Resort Public Water Supply [17155] | 04-Sep-09 Sunrise Regional Health Authority | PDWA for Canora Beach Resort Public Water Supply [17155] due to the presence of coliform bacteria | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Carson South Camp [15203] | 07-Jun-07 Mamawetan Churchill River Regional Health Authority | EBWO for Carson's South Camp due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|-------------------------------|--|---|------|------|---|
| Carson South Camp [15203] | 21-Jun-08 Mamawetan Churchill River Regional Health Authority | EBWO for Carson South Camp due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| CCJ Well Water Supply [14258] | 12-Jul-11 No. 4 - Regina Qu'Appelle Regional Health Authority | EBWO downgraded to PDWA Craven Country Jamboree Well due to coliforms in drinking water | 1 | | Operational: Treatment unable to cope with significant deterioration in source water quality Quality: Unacceptable turbidity or particle counts in treated water |
| Cedar Lodge (24644) | 10-May-11 Saskatoon Regional Health Authority | Cedar Lodge - PW, PDWA. Follow up done on May 10, 2010 by Brent Latimer. | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:01 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|---|
| Cherrydale Golf and Campground | 15-Jun-07 Sunrise Regional Health Authority | PDWA issued for Cherrydale Golf and Campground due to poor bacteriological results | 1 | | Operational: Quality: Suspected contamination |
| Chilly's Pub and Grill (RM No. 183) | 25-Jun-09 Sunrise Regional Health Authority | PDWA issued for Chilly's Pub and Grill (RM No. 183) due to the presence of coliform bacteria | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Christopher Lake Housing Authority (Manor) [516] | 01-Jun-10 Prince Albert Parkland Regional Health Authority | Christopher Lake Manor EBWO | | 1 | Operational: Contamination during construction, repair or operation Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|--|------|------|--|
| Churchill River Voyageur Lodge [15570] | 24-Jun-11 Mamawetan Churchill River Regional Health Authority | EBWO Churchill River Voyager Lodge - upgraded from existing PDWA | | 1 | Operational: Quality: E.coli detected in drinking water system |
| Churchill River Wilderness Camps [14673] | 24-Jun-11 Mamawetan Churchill River Regional Health Authority | EBWO for Churchill River Wilderness Camp due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Clarke Lake Lodge [12634] | 17-Jul-09 Mamawetan Churchill River Regional Health Authority | PDWA for Clarke Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|--|
| Clearwater Lake Hotel - Clearwater Lake Regional Park | 19-May-11 Heartland Regional Health Authority | PDWA Clearwater Lake Hotel- issue due to the absence of water sample submissions | 1 | | Operational: Does not meet reporting requirements Quality: Suspected contamination |
| Collins Camps & Outfittings Inc. - Cabin Lodges [14516] | 13-Jun-08 Mamawetan Churchill River Regional Health Authority | PDWA for Collins Camp & Outfitters Inc. (Besnard Lake) due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Collins Camps & Outfittings Inc. - Kitchen [21959] | 13-Jun-09 Mamawetan Churchill River Regional Health Authority | PDWA for Collins Camps & Outfittings Inc. - Kitchen [21959] due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|-----------------------------------|--|---|------|------|--|
| Cowan Dam Campground [17238] | 30-May-08 Mamawetan Churchill River Regional Health Authority | PDWA for Cowan Lake Campground due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Cree Lake Lodge 2009 Ltd. [15708] | 25-Jun-10 Mamawetan Churchill River Regional Health Authority | PDWA for Cree Lake Lodge 2009 Ltd. due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Cree River Lodge Inc. [15027] | 17-Jul-09 Mamawetan Churchill River Regional Health Authority | EBWO for Cree River Lodge Inc. due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|---|
| Crystal Lake Golf & Country Club Inc. Public Water Supply [13854] | 17-Jun-09 Sunrise Regional Health Authority | PDWA for Crystal Lake Golf & Country Club Inc Public Water Supply [13854] due to high nitrate count. | 1 | | Operational: Quality: Exceedance of MAC or drinking water standard |
| Crystal Lodge Ltd. [15361] | 28-Jun-10 Mamawetan Churchill River Regional Health Authority | EBWO - Crystal Lodge Ltd. Ispatamow Island, Cree Lake - existing PDWA amended to EBWO | | 1 | Operational: Quality: Total coliforms detected in drinking water system |
| D & D Camps [20860] | 14-Jun-08 Mamawetan Churchill River Regional Health Authority | EBWO for D & D Camps due to E.coli - Duplex Cabin KS | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|---|--|------|------|--|
| Danbury Community Well [13741] Clayton, RM of #333, Facility #13741 | 22-Jun-07 Sunrise Regional Health Authority | PDWA for Danbury Community Well [13741] Clayton, RM of #333 due to poor bacteriological results. | 1 | | Operational: Quality: Exceedance of MAC or drinking water standard |
| Deception Lake Lodge [15772] | 04-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for Deception Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Deschambault Lake Resort [12334] | 08-Jul-11 Mamawetan Churchill River Regional Health Authority | EBWO for Deschambault Lake Resort due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|--|
| Domremy Beach Resort Well [6482] | 16-Apr-11 Saskatoon Regional Health Authority | Domremy Beach Resort Well [6482], PDWA, April 11, 2011. Michael Newell to follow up. | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: |
| Drinking Falls Lodge [14696] | 24-Jun-10 Mamawetan Churchill River Regional Health Authority | EBWO issued for Drinking Falls Lodge [14696] | | 1 | Operational: No or inadequate disinfection at the treatment plant Quality: |
| Ebon Stables Concession - Cistern [17284] | 16-Apr-10 Saskatoon Regional Health Authority | PDWA for Ebon Stables Concession - Cistern due to seasonal startup | 1 | | Operational: Does not meet monitoring requirements Quality: Suspected contamination |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|--|------|------|--|
| Edam Community Recreation Centre Water Supply [1557] | 02-Mar-11 Prairie North Regional Health Authority | PDWA - Edam Community Recreation Centre, Edam SK | 1 | | Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system |
| Ena Lake Lodge [15024] | 04-Jul-07 Mamawetan Churchill River Regional Health Authority | PDWA for Ena Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Eston Regional Park Water Supply [15595] | 21-May-10 Heartland Regional Health Authority | Eston Regional Park PDWA | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Suspected contamination |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|-------------------------------------|--|--|------|------|---|
| Foster River Camps [15159] | 20-Jun-09 Mamawetan Churchill River Regional Health Authority | EBWO for Foster River Camps due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| George Lake Camp Outfitting [15654] | 10-Jun-06 Mamawetan Churchill River Regional Health Authority | EBWO for George Lake Camp Outfitting due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Glen Harbour Kids Camp Well [9881] | 26-May-10 No. 4 - Regina Qu'Appelle Regional Health Authority | PDWA Glen Harbour Kids Camp | 1 | | Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|---|---|------|------|---|
| Good Spirit Bible Camp - Well [13694] NE 08-29-05 W2 | 15-Jul-08 Sunrise Regional Health Authority | PDWA Good Spirit Bible Camp Well - issued due to lack of water sampling. | 1 | | Operational: Does not meet monitoring requirements Quality: |
| Good Spirit Lake Provincial Park Recreation Hall - Well [13884] | 20-Mar-08 Sunrise Regional Health Authority | PDWA for Good Spirit Lake Provincial Park Recreation Hall - Well [13884] due to a lack of sampling. | 1 | | Operational: Does not meet reporting requirements Quality: |
| Grand Slam Lodge [15016] | 16-Jul-07 Mamawetan Churchill River Regional Health Authority | EBWO for Grand Slam Lodge due to detection of E. coli and total coliforms | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|--|
| Green Acres Golf & Country Club Well [9882] | 27-Aug-10 No. 4 - Regina Qu'Appelle Regional Health Authority | PDWA - Green Acres Golf and Country Club | 1 | | Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system |
| Green Lake Lodge [14556] | 02-Jul-09 Mamawetan Churchill River Regional Health Authority | EBWO for Green Lake Lodge due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Harvelle House Water Supply [2811] | 29-Nov-11 Prairie North Regional Health Authority | Harvelle House PDWA | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---------------------------------------|--|--|------|------|--|
| Haskins Bay Fly-in [12683] | 17-Jun-11 Mamawetan Churchill River Regional Health Authority | PDWA issued on Haskins Bay Fly-in due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Hawkrock Wilderness Adventure [15003] | 04-Jul-07 Mamawetan Churchill River Regional Health Authority | PDWA for Hawkrock Wilderness Adventure Ltd. due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Hepburn Arena Well [6661] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Hepburn Arena Well | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|--|
| Hepburn Co-op Well [6664] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Hepburn Co-op Well | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| Hepburn Housing Authority Well #1 [14649] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Hepburn Housing Authority - Well #1 | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| Hepburn Housing Authority Well #2 [14651] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Hepburn Housing Authority - Well #2 | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|---|------|------|--|
| Hepburn Housing Authority Well #3 [14654] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Hepburn Housing Authority - Well #3 | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| Hepburn Housing Authority Well #4 [14660], Hepburn Housing Authority Well #5 [14664], Hepburn Housing Authority Well #6 [14666], Hepburn Housing Authority Well #7 [14669], Hepburn Housing Authority Well #8 [14670], Hepburn Housing Authority Well #9 [14671], Hepburn Housing Authority Well #10 [14672], Hepburn Housing Authority Well #11 [14674], Hepburn Housing Authority Well #12 | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Hepburn Housing Authority - Wells 4-14 | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---------------------------------|--|--|------|------|--|
| Hepburn Lake Lodge Ltd. [15597] | 29-May-06 Mamawetan Churchill River Regional Health Authority | EBWO for Hepburn Lake Lodge Ltd. due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Hepburn School - Well [6668] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Hepburn School Well | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| Hinchliffe RM - Well [13800] | 30-Jul-09 Sunrise Regional Health Authority | PDWA issued for Hinchliffe RM - Well [13800] due to the presence of bacteria | 1 | | Operational: Quality: Exceedance of MAC or drinking water standard |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|---|--|------|------|--|
| Indian Head Camp Adventures [15245] | 30-Jul-10 Mamawetan Churchill River Regional Health Authority | EBWO for Indian Head Camp Adventures due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Jack Pine Stables - Well [17444] | 01-Oct-09 Saskatoon Regional Health Authority | PDWA - Jack Pine Stables | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| Jan Lake Convenience Store [15974] | 02-Sep-11 Mamawetan Churchill River Regional Health Authority | Jan Lake Convenience Store | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|---|------|------|---|
| Jims Camps [15228] | 29-May-06 Mamawetan Churchill River Regional Health Authority | EBWO for Jim's Camp due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Jims Meats - Water Supply [14858] Jims Meats - food processor | 27-Jan-12 Heartland Regional Health Authority | PDWA Jim's Meats - SW 28-38-24W3M in the Rural Municipality of Grass Lake # 381 | 1 | | Operational: No or inadequate disinfection at the treatment plant Quality: Total coliforms detected in drinking water system |
| Johnson River Camp [23361] | 07-Jun-10 Mamawetan Churchill River Regional Health Authority | EBWO for Johnson River Camp due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---------------------------------|--|---|------|------|--|
| Jug Bay Sport Fishing [21119] | 30-Jul-10 Mamawetan Churchill River Regional Health Authority | EBWO for Jug Bay Sport Fishing due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Kamkota Lodge [12726] | 31-May-08 Mamawetan Churchill River Regional Health Authority | EBWO for Kamkota Lodge Cabin #2 due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Kandahar Waterworks Well [6631] | 29-Apr-10 Saskatoon Regional Health Authority | PDWA - Kandahar Waterworks due to total coliforms | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--------------------------|--|---------------------------------------|------|------|--|
| Keefe Lake Camp [15208] | 14-Jul-11 Mamawetan Churchill River Regional Health Authority | Keefe Lake Camps | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Kennedy Well [8421] | 24-Jun-10 Sun Country Regional Health Authority | EBWO issued for Kennedy Well in RM 93 | | 1 | Operational: Quality: E.coli detected in drinking water system |
| Kingfisher Lodge [15598] | 11-Jun-11 Mamawetan Churchill River Regional Health Authority | PDWA issued on Kingfisher Lodge | 1 | | Operational: Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| Koffee Korner - Well [6765] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Koffee Korner - Well | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| La Fleur Outdoor Adventures [14681] | 14-Jul-09 Mamawetan Churchill River Regional Health Authority | EBWO for Lafleur Outdoor Adventures due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Lady Lake Hamlet - Well [13799] RM of Preeceville #334, SE 27-35-5-W2M | 30-Jul-09 Sunrise Regional Health Authority | PDWA for Lady Lake Hamlet - Well [13799] due to high nitrate count. | 1 | | Operational: Quality: Exceedance of MAC or drinking water standard |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|---|---|------|------|---|
| Lady Lake Regional Park - Well [13511] RM of Preeceville #334 | 15-Jun-09 Sunrise Regional Health Authority | PDWA for Lady Lake Regional Park - Well RM of Preeceville #333 due to the presence of bacteria. | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Lady Lake RM - Well [13803] Preeceville, RM of (NW 23-35-5-W2nd) | 28-Jun-07 Sunrise Regional Health Authority | EBWO for Lady Lake RM - Well [13803] Preeceville due to presence of total coliform and E.Coli. | | 1 | Operational: Quality: E.coli detected in drinking water system |
| Lake Athabasca Lodge [15383] | 26-Jun-06 Mamawetan Churchill River Regional Health Authority | EBWO for Lake Athabasca Lodge due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|---|------|------|--|
| Langenburg, RM of #181 | 11-Jun-09 Sunrise Regional Health Authority | PDWA for Langenburg, RM of #181 due to the presence of coliform bacteria. | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Lindberghs Reindeer Lake Lodge [15132] | 16-Jul-07 Mamawetan Churchill River Regional Health Authority | PDWA for Lindbergh's Reindeer Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Lloyd Lake Lodge Ltd. [15684] | 16-Jun-06 Mamawetan Churchill River Regional Health Authority | EBWO for Lloyd Lake Lodge Ltd. - N 57.33715 due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|----------------------------------|--|--|------|------|---|
| Lloyd Lake Lodge Ltd. [15684] | 15-Jun-06 Mamawetan Churchill River Regional Health Authority | EBWO for Lloyd Lake Lodge Ltd. due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Lone Wolf Camps [15903] | 25-Jun-07 Mamawetan Churchill River Regional Health Authority | EBWO for Lone Wolf Camps due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Luseland Campground Well [23333] | 02-Jul-10 Heartland Regional Health Authority | PDWA - Luseland Campground | 1 | | Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| MacPherson Lake Lodge [14986] | 29-May-06 Mamawetan Churchill River Regional Health Authority | EBWO for MacPherson Lake Lodge due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Manewan Enterprises Ltd. - Marchel Lake [15730] | 25-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for Manewan Enterprises Ltd. - Marchel Lake due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Manewan Enterprises Ltd. - Nemei Lake [15719] | 24-Jun-11 Mamawetan Churchill River Regional Health Authority | PDWA issued on Manewan Enterprises Ltd. - Nemei Lake - total coliforms detected in drinking water | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|---|------|------|--|
| Meadows Edge Bed and Breakfast [21301] RM of Preeceville #334, NE 11-35-6 W2M | 30-Jul-09 Sunrise Regional Health Authority | PDWA for Meadows Edge Bed and Breakfast [21301] RM of Preeceville due to the presence of bacteria | 1 | | Operational: Quality: Exceedance of MAC or drinking water standard |
| Milton Lake Lodge [15324] | 26-Jun-06 Mamawetan Churchill River Regional Health Authority | EBWO for Milton Lake Lodge due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Minor Bay Lodge [15010] | 22-Jun-10 Mamawetan Churchill River Regional Health Authority | PDWA for Minor Bay Lodge & Outpost Ltd - Spencer Lake Outpost due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---------------------------------|--|---|------|------|--|
| Missy's Restaurant [7277] | 11-Aug-11 Saskatoon Regional Health Authority | PDWA, Missy's Restaurant [7277]. Repeat sample with TC. Follow up done by DD. | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Morning Lake Outfitters [16118] | 14-Jun-07 Mamawetan Churchill River Regional Health Authority | EBWO for Morning Lake Outfitters due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Navau Park Water Supply [8667] | 23-Jun-11 Sun Country Regional Health Authority | EBWO issued to Navau Trailer Park due to flooding | | 1 | Operational: Treatment unable to cope with significant deterioration in source water quality Quality: Significant deterioration of source water quality due to environmental conditions |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|-----------------------------------|--|---|------|------|--|
| Norseman Outfitters [17572] | 21-Apr-11 Prince Albert Parkland Regional Health Authority | Norseman Outfitting EBWO due to E.coli | | 1 | Operational: Does not meet reporting requirements Quality: E.coli detected in drinking water system |
| Northern Echo Lodge [13963] | 26-Jun-06 Mamawetan Churchill River Regional Health Authority | EBWO for Northern Echo Lodge due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Northern Reflection Lodge [15265] | 22-Jun-10 Mamawetan Churchill River Regional Health Authority | PDWA for Northern Reflection Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|---|------|------|--|
| OBriens Fly-in Careen Lake Lodge [16081] | 13-Jun-08 Mamawetan Churchill River Regional Health Authority | PDWA for O'Brien's Fly-in Careen Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Osin Community Well [13767] | 14-Sep-07 Sunrise Regional Health Authority | PDWA issued for Osin Community Well [13767] due to the presence of coliform | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Park Lane Water Pipeline [17304] | 30-Jan-12 Five Hills Regional Health Authority | PDWA Issued for Park Lane Water Pipeline | 1 | | Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|-------------------------------------|--|---|------|------|--|
| Paull River Wilderness Camp [12523] | 17-Jun-09 Mamawetan Churchill River Regional Health Authority | EBWO for Paull River Wilderness Camps due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Pawistik Lodge Inc. [12223] | 04-Jun-02 Mamawetan Churchill River Regional Health Authority | EBWO issued for Pawistik Lodge Inc. [12223] | | 1 | Operational: No or inadequate disinfection at the treatment plant Quality: |
| Phantom Lake Golf Club Inc. [12498] | 01-Aug-10 Mamawetan Churchill River Regional Health Authority | PDWA Phantom Lake Golf Course MCRRHA | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|--|------|------|--|
| Phantom Lake Golf Club Inc. [12498] | 01-Aug-10 Mamawetan Churchill River Regional Health Authority | PDWA for Phantom Lake Golf Club Inc. due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Phil Foster Wilderness Fishing [15819] | 25-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for Phil Foster Wilderness Fishing due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Pickerel Bay Cabins Ltd. [15268] | 11-Jun-10 Mamawetan Churchill River Regional Health Authority | EBWO for Pickerel Bay Cabins Ltd. due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|---|------|------|--|
| Pilots Lodge [17110] | 01-Jul-07 Mamawetan Churchill River Regional Health Authority | EBWO for Pilot's Lodge due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Pine Point Lodge & Outpost - Athapapuskow Lake [14162] | 08-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for Pine Point Lodge & Outpost due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Pipestone Lake Fishing Lodge Inc. [12506] | 25-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for Pipestone Lake Fishing Lodge Inc. due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| Pointer Lake Lodge Ltd. [12548] | 04-Jun-10 Mamawetan Churchill River Regional Health Authority | PDWA for Pointer Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Prairie Lake Regional Park Water Supply [23306] | 21-May-10 Heartland Regional Health Authority | Prairie Lake Regional Park Water System PDWA due to lack of treatment | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Suspected contamination |
| Prill Lake Lodge [15899] | 13-Jun-08 Mamawetan Churchill River Regional Health Authority | PDWA for Prill Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---------------------------------------|--|--|------|------|--|
| Prince Public Well [11268] | 14-May-04 Prairie North Regional Health Authority | Prince Public Well, Bacterial Contamination (EBWO) | | 1 | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| R & R Wilderness Lodge [14036] | 05-Jun-09 Mamawetan Churchill River Regional Health Authority | PDWA for R & R Wilderness Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| R.M. #96 - Well 4 (Hand Pump) [15338] | 29-Apr-11 Sun Country Regional Health Authority | PDWA issued for RM 96 Well #4 due to detection of total coliform | 1 | | Operational: Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|------------------------------------|--|--|------|------|--|
| Readlyn Water Co-operative [16221] | 30-Jul-09 Five Hills Regional Health Authority | Readlyn Water Co-op PDWA | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Suspected contamination |
| Riverside Hotel - Water [8732] | 21-Dec-09 Sun Country Regional Health Authority | PDWA for Riverside Hotel in Gainsborough due to presence of total coliforms | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| RM 340 Community Well #1 [6139] | 28-Aug-09 Saskatoon Regional Health Authority | PDWA issued for RM 340 Community Well #1 [6139] (Wolverine) due to total coliforms | 1 | | Operational: Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| Rural Municipality of Buchanan No. 304 - Well (NE 33-33-5 W2) [13624] | 16-Jun-10 Sunrise Regional Health Authority | EBWO for Rural Municipality of Buchanan No. 304 - Well (NE 33-33-5 W2) [13624] due to E.coli | | 1 | Operational: Quality: E.coli detected in drinking water system |
| Rural Municipality of Buchanan No. 304 - Well (SE 23-32-4-W2) [13621] | 25-Mar-11 Sunrise Regional Health Authority | PDWA for R.M. of Buchanan Well No. 4 (SE-23-32-4 - Est.#13621) replaces EBWO of May 13, 2010 | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Rural Municipality of Saltcoats No. 213 - Public Well [13403] Well #1, NW 13-24-3-W2nd | 10-Oct-07 Sunrise Regional Health Authority | PDWA for RM of Saltcoats No. 213 - Public Well #1 [13403] due to the presence of coliform bacteria. | 1 | | Operational: Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|--|------|------|---|
| Rural Municipality of Sliding Hills No. 273 - Well No. 1 [13625] | 07-Oct-10 Sunrise Regional Health Authority | EBWO issued to R.M.#273 - Sliding Hills Community Well#1 (Donwell) due to detection of E. coli | | 1 | Operational: Quality: E.coli detected in drinking water system |
| Rural Municipality of Sliding Hills No. 273 - Well No. 4 (Petriw Well) [13628] | 13-Jul-07 Sunrise Regional Health Authority | PDWA for RM of Sliding Hills No. 273 - Well No. 4 (Petriw Well) [13628] due to high nitrate levels | 1 | | Operational: Quality: Exceedance of MAC or drinking water standard |
| Sandyridge Gas and Grocery - Well [14833] | 21-Oct-11 Saskatoon Regional Health Authority | PDWA Sandy Ridge Gas and Grocery, Follow up by DL Oct 21, 2011. | 1 | | Operational: No or inadequate disinfection at the treatment plant Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|--|------|------|---|
| Saskairie Outdoor Centre Well [8662] | 23-Sep-11 Sun Country Regional Health Authority | PDWA issued for Saskairie Outdoor Centre Well due to presence of total coliforms | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Scott Lake Lodge Ltd. [15144] | 13-Jul-10 Mamawetan Churchill River Regional Health Authority | EBWO for Scott Lake Lodge Ltd. due to E. coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Shannon Lake Campground Cistern [14534] | 16-Apr-10 Saskatoon Regional Health Authority | PDWA for Shannon Lake Campground Cistern due to total coliforms | 1 | | Operational: Does not meet monitoring requirements Quality: Suspected contamination |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| Silence of the North Hunting & Fishing Inc. [12159] | 27-Jul-11 Mamawetan Churchill River Regional Health Authority | Silence of the North Hunting & Fishing Inc. | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Slim's Cabins Ltd. - Golden Lake | 20-Jun-11 Mamawetan Churchill River Regional Health Authority | EBWO for Slim's Cabins Ltd. - Golden Lake due to E.Coli and inadequate disinfection | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Slim's Cabins Ltd. - Laurie Lake [13982] | 27-Jun-09 Mamawetan Churchill River Regional Health Authority | EBWO for Slim's Cabins - Laurie Lake due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|---|
| Slim's Cabins Ltd. -Scotties Beach [13972] | 25-Jun-07 Mamawetan Churchill River Regional Health Authority | EBWO for Russell's Churchill River Camp Ltd - Scotties Beach due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Slims Cabins - Kipahigan Lake [13956] | 10-Jun-11 Mamawetan Churchill River Regional Health Authority | EBWO for Slim's Cabins - Kipahigan Lake due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Slims Cabins Ltd. - Tomahawk Lake Outpost [12418] | 20-Jun-11 Mamawetan Churchill River Regional Health Authority | EBWO for Slim's Cabins Ltd. - E. coli detected in Tomahawk Lake Outpost drinking water system | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| Slims Cabins. - Kamuchawie Lake [13978] | 20-Jun-11 Mamawetan Churchill River Regional Health Authority | PDWA Issued at Slim's Cabins Ltd. - Kamuchawie Lake - due to detection of total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| South Bay Outfitters Ltd. [15672] | 09-Aug-10 Mamawetan Churchill River Regional Health Authority | EBWO issued for South Bay Outfitters Ltd. [15672] due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Spring Bay Lodge [15127] | 13-Jul-10 Mamawetan Churchill River Regional Health Authority | PDWA for Lakers Unlimited Inc. - Spring Bay Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---------------------------------------|---|--|------|------|--|
| Stornoway Public Well [13647] | 30-Jul-10 Sunrise Regional Health Authority | PDWA - Stornoway Public Well | 1 | | Operational: Treatment unable to cope with significant deterioration in source water quality Quality: Total coliforms detected in drinking water system |
| Sunshine Fairways [20761] | 12-Aug-09 Prince Albert Parkland Regional Health Authority | PDWA for Sunshine Fairways [20761] | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: |
| Swedes Bed N Breakfast - Well [13478] | 20-Jun-08 Sunrise Regional Health Authority | PDWA: Swedes Bed N Breakfast - Well 13478 due to total coliform bacteria & lack of water sampling. | 1 | | Operational: Does not meet monitoring requirements Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|------------------------------------|--|--|------|------|--|
| T & D Amisk Cabins Inc. [12136] | 01-Aug-10 Mamawetan Churchill River Regional Health Authority | PDWA for T & D Amisk Cabins Inc. due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Tanks Country Meats - Well [13825] | 14-Dec-07 Sunrise Regional Health Authority | PDWA issued to Tanks Country Meats - Well [13825] due to the presence of coliform bacteria | 1 | | Operational: Quality: Total coliforms detected in drinking water system |
| Tate Island Lodge [14080] | 19-Jul-08 Mamawetan Churchill River Regional Health Authority | EBWO for Tate Island Lodge due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|---|---|------|------|--|
| The New Canoe Lake West Resort 1987 [16087] | 11-Sep-10 Mamawetan Churchill River Regional Health Authority | PDWA for The New Canoe Lake West Resort 1987 due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Theodore Motor Hotel - Well [13652] | 07-Mar-08 Sunrise Regional Health Authority | PDWA for Theodore Motor Hotel - Well [13652] inadequate number of water samples | 1 | | Operational: Does not meet monitoring requirements Quality: |
| Thompson's Camps - Daly Lake Outpost [15576] | 16-Jun-10 Mamawetan Churchill River Regional Health Authority | EBWO for Thompson's Camp - Daly Lake Outpost due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--|--|--|------|------|--|
| Thompson's Camps - Upper Foster Lake Outpost [16540] | 20-Jun-09 Mamawetan Churchill River Regional Health Authority | PDWA for Thompson's Camps - Upper Foster Lake Outpost due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Thunder Mountain Outfitting [21930] | 06-Jun-09 Mamawetan Churchill River Regional Health Authority | EBWO for Thunder Mountain Outfitting due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Top of the Rock Adventures [23552] | 17-Jun-10 Mamawetan Churchill River Regional Health Authority | PDWA for Top of the Rock Adventures due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|--------------------------------|--|--|------|------|--|
| Tower Lodge Outfitting [16108] | 14-Jul-09 Mamawetan Churchill River Regional Health Authority | EBWO for Tower Lodge Outfitting due to E.coli | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Triveet Lake Lodge [14975] | 21-Jun-08 Mamawetan Churchill River Regional Health Authority | PDWA for Triveet Lake Lodge due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Trout Lake Camp [15276] | 17-Aug-07 Mamawetan Churchill River Regional Health Authority | PDWA for Trout Lake Camp due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|---|
| True North Lodge [17361] | 20-Jun-08 Mamawetan Churchill River Regional Health Authority | EBWO issued for True North Lodge [17361] | | 1 | Operational: Quality: E.coli detected in drinking water system |
| Tuffnell Recreation Centre - Well [13428] | 18-Oct-07 Sunrise Regional Health Authority | EBWO for Tuffnell Recreation Centre - Well [13428] due to the presence of total coliform and E.Coli | | 1 | Operational: Quality: E.coli detected in drinking water system |
| Tuxford Rural Water Supply Pipeline [17308] | 06-Jul-09 Five Hills Regional Health Authority | Tuxford Rural Water Pipeline PDWA | 1 | | Operational: Does not meet monitoring requirements Quality: |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|----------------------------------|--|--|------|------|--|
| Twin Bay Resort Ltd. [16112] | 02-Sep-11 Mamawetan Churchill River Regional Health Authority | Twin Bay Resort Ltd. | | 1 | Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system |
| Ubiquity Lake Outfitters [15879] | 25-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for Ubiquity Lake Outfitters due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Verwood Water Inc. [16364] | 05-Aug-08 Five Hills Regional Health Authority | Verwood Water Inc PDWA | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Suspected contamination |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|--|---|------|------|--|
| Village of Hepburn - well [21514] | 02-Nov-09 Saskatoon Regional Health Authority | PDWA - Village of Hepburn Well | 1 | | Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system |
| VJ's Fishing Lodge Ltd. [12608] | 08-Jun-07 Mamawetan Churchill River Regional Health Authority | PDWA for V.J. Fishing Camp due to total coliforms | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system |
| Wood Mountain Regional Park Well - Pool [11262] | 18-Jun-10 Five Hills Regional Health Authority | Wood Mountain Regional Park PDWA | 1 | | Operational: Quality: Total coliforms detected in drinking water system |

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 3 Feb 2012 17:20:02 CST

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

| Public Water Supply | Date Issued and Regional Health Authority | Title | PDWA | EBWO | Comments |
|---|---|--|------------|-----------|---|
| Wood Mountain Regional Park Well - Showers [11263] | 08-Jun-11 Five Hills Regional Health Authority | PDWA Issued for Wood Mountain Regional Park Shower Well | 1 | | Operational: Inadequate disinfection residual in distribution system Quality: Unacceptable turbidity or particle counts in treated water |
| York Lake Golf & Country Club Inc. - Well No. 2 [16730] | 17-May-11 Sunrise Regional Health Authority | Amendment- York Lake Golf & Country Club EBWO replaced by PDWA | 1 | | Operational: Treatment / distribution equipment failure or damage Quality: Suspected contamination |
| Totals: | | | 112 | 63 | |
| Advisories/Orders Currently in Effect: | | | 175 | | |